

Fridge Temperature Log of VGHTC Clinical Trial Pharmacy

(Normal Range: 2~8°C)

PHCL-C001 (Model: TIT / TR200)

Thermograph: ESCORT,1043-0065

Date (dd-mmm-yy)	Current (AM)			Current (PM)			Max. & Min.			Comments
	Time (hh:mm)	Temp (°C)	Signature (Initials)	Time (hh:mm)	Temp (°C)	Signature (Initials)	Max.Temp (°C)	Min.Temp (°C)	Signature (Initials)	
01-Aug-17	09:25	4.1	NTN	17:25	5.6	STW	5.9	3.9	NTN	
02-Aug-17	08:10	5.1	NTN	17:05	4.4	STW	6.4	3.8	NTN	
03-Aug-17	08:11	4.4	NTN	17:00	5.2	STW	5.4	3.6	NTN	
04-Aug-17	08:05	5.1	NTN	17:00	5.3	STW	5.6	3.6	NTN	
07-Aug-17	08:10	3.9	STW	17:10	4.1	STW	6.0	3.9	NTN	
08-Aug-17	08:05	5.3	STW	17:55	5.1	STW	6.2	3.8	NTN	
09-Aug-17	08:10	6.4	STW	17:25	4.3	STW	6.4	3.9	NTN	
10-Aug-17	08:05	4.3	STW	17:40	4.6	STW	6.1	3.3	NTN	
11-Aug-17	08:05	5.3	STW	17:25	3.8	STW	5.6	3.7	NTN	
14-Aug-17	08:57	3.8	NTN	17:05	5.2	STW	6.3	3.8	NTN	
15-Aug-17	08:05	3.9	NTN	17:05	3.9	STW	6.2	3.7	NTN	
16-Aug-17	08:03	4.0	NTN	17:00	3.8	STW	6.2	3.6	NTN	
17-Aug-17	08:20	5.0	STW	17:25	4.1	STW	5.7	3.6	NTN	
18-Aug-17	08:55	5.2	NTN	17:30	4.1	NTN	6.2	3.7	NTN	
21-Aug-17	08:55	4.4	NTN	18:15	5.1	NTN	6.1	3.9	NTN	
22-Aug-17	07:49	4.9	NTN	18:38	5.1	NTN	5.6	3.6	NTN	
23-Aug-17	08:46	4.8	NTN	17:35	4.8	NTN	5.1	3.4	NTN	
24-Aug-17	08:00	4.5	NTN	17:30	3.8	NTN	5.8	3.4	NTN	
25-Aug-17	08:07	4.9	NTN	17:38	4.4	NTN	5.7	3.3	NTN	
28-Aug-17	10:23	4.6	NTN	17:13	3.7	STW	5.1	3.2	NTN	
29-Aug-17	08:30	3.8	NTN	17:20	4.1	STW	5.8	3.4	NTN	
30-Aug-17	08:28	4.6	NTN	17:00	5.0	STW	6.2	3.5	NTN	
31-Aug-17	08:45	4.6	NTN	17:25	5.0	STW	6.0	3.6	NTN	

Noted by 04 Sep 2017